

LCB File No. R077-99

PROPOSED REGULATION

OF THE STATE BOARD OF HEALTH

EXPLANATION – Matter in *italics* is new; matter in brackets ~~[omitted material]~~ is material to be omitted.

AUTHORITY: NRS 445A.855 and 445A.860.

NAC 445A.485 Reporting, public notification and recordkeeping

1. The owner or operator of a public water system who fails to perform monitoring as required by *40 C.F.R.* § 141.21 of the “National Primary Drinking Water Regulations ” shall notify all persons served by the system within 45 days of the violation or failure. All other activities of reporting, public notification and recordkeeping must be performed as required by *40 C.F.R.* §§ 141.31 to 141.35, inclusive, *by 40 C.F.R. §§ 141.151 to 141.155, inclusive,* of the “National Primary Drinking Water Regulations” and by NAC 445A.450 to 445A.492, inclusive.

2. Daily turbidity measurements must be compiled on a monthly basis and analyzed as required by *40 C.F.R.* § 141.22 of the “National Primary Drinking Water Regulations. The compiled results must be sent to the health division before the 10th day of the following month. Water suppliers located in Clark County or Washoe County must report to the applicable district health department.

Note: New language is indicated by italics. The additions of “40 C.F.R.” to existing language in sections 1 and 2 clarify that the references are to Title 40, Code of Federal Regulations.